

Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 8832839 - Fax (208) 8829246 - email moscow@anateklabs.com
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - fax (509) 838-4433 - email spokane@anateklabs.com

Lab Federal ID#: **See Below** Lab/Sample Number: **MAC0261-07**
Date Received: **03/25/2020** Date Reported by Lab: **04/21/2020**
Compliance Sample: **Yes** Replacement Sample: **No**
Collect Date: **03/25/2020** Collection Time: **11:26**
Sample Type:
PWS#: PWS Name: **Panhandle Health District**
Sample Point/ Location: **132-ID1280084/WELL1** Tag#/Facility ID:
Contact Name: **Jenny Gray** Contact Phone: **208-883-2839**
Lab Federal ID#: **ID00013**

Public Drinking Water System Analysis Report

Inorganics

FRDS	Analyte	Result	Units	MCL	MRL	Analyzed	Analyst	Method	Qualifier
1026	Bicarbonate	181	mg CaCO3/L		2.00	4/2/20 17:10	LAC	SM 2320 B	
1930	TDS	233	mg/L	500	50.0	4/1/20 10:37	LAC	SM 2540 C	

Public Drinking Water System Analysis Report

Metals by ICP-MS

FRDS	Analyte	Result	Units	MCL	MRL	Analyzed	Analyst	Method	Qualifier
1005	Arsenic	0.00127	mg/L	0.01	0.00100	3/31/20 18:31	MYM	EPA 200.8	
1030	Lead	ND	mg/L	0.015	0.00100	3/31/20 18:31	MYM	EPA 200.8	

Public Drinking Water System Analysis Report

Metals by ICP

FRDS	Analyte	Result	Units	MCL	MRL	Analyzed	Analyst	Method	Qualifier
1016	Calcium	57.1	mg/L		0.100	4/2/20 13:43	MYM	EPA 200.7	
1031	Magnesium	9.20	mg/L		0.100	4/2/20 13:43	MYM	EPA 200.7	
1052	Sodium	4.55	mg/L		0.100	4/2/20 13:43	MYM	EPA 200.7	

Lab Federal ID#: **WA00169**

Public Drinking Water System Analysis Report

Inorganics

FRDS	Analyte	Result	Units	MCL	MRL	Analyzed	Analyst	Method	Qualifier
1017	Chloride	7.82	mg/L	250	0.100	3/26/20 0:03	SST	EPA 300.0	
1040	Nitrate/N	1.96	mg/L	10	0.100	3/26/20 0:03	SST	EPA 300.0	
1055	Sulfate	5.83	mg/L	250	0.100	3/26/20 0:03	SST	EPA 300.0	