Panhandle Health District

Aquifer Monitoring Project	
Sampling Report	Sample Date Jan. 30 & 31, 2012

Temp in degrees C, Conductivity in micromhos, other values in milligrams per liter (mg/l)"

PHD#	Site Name	PWS NUMBER	Arsenic-	Iron	Hardness	NO3as N	Chloride	Conductivity	p H	Sulfates	Calcium	Mag	TEMP	VOC's Type	VOC Value
			FRDS 1005	FRDS 1028	FRDS 1915	FRDS 1040	FRDS 1017	FRDS 1064	FRDS 1925	FRDS 1055	FRDS 1016	FRDS 1031			ug/l
119	ATHOL #1 GROVE AVE	1280006	0.00215	0.0100	141	2.06	5.41	344	7.82	16.0	32.3	14.7	8.7	Not Tested for VOCs	na
99	CDA-4TH STREET	1280053	0.00213	nd	117	1.01	8.17	327	7.27	8.19	26.5	12.4	12.8	Tested < MDL	0
130	CDA-HONEYSUCKLE	1280053	0.00278	nd	115	0.747	4.23	389	7.78	8.88	24.8	12.8	114	Tested < MDL	0
114	CHS	0	0.00469	0.0585	134	1.24	3.30	298	7.56	12.9	30.0	14.2	11.3	Tested < MDL	0
111	DALTON GARDENS #1 E	1280059	0.00268	nd	146	1.86	7.08	345	7.64	8.14	37.6	12.6	9.0	Tested < MDL	0
112	EAST GREENACRES	1280064	0.00434	nd	131	1.49	3.32	327	7.95	13.9	28.9	14.3	6.1	Not Tested for VOCs	na
118	FARRAGUT	1280069	0.00260	nd	121	0.164	1.25	293	7.92	13.0	27.6	12.7	10.5	Not Tested for VOCs	na
132	HAUSER	1280084	0.00136	nd	160	1.18	4.97	374	7.51	5.48	50.0	8.56	8.9	Not Tested for VOCs	na
125	L.A. ALUMINUM	0	nd	nd	88.6	0.611	2.38	282	7.6	5.12	22.7	7.74	9.1	Tested < MDL	0
113	MTN. VIEW TERRACE	1280123	0.00673	0.260	138	1.75	3.84	301	7.73	11.0	30.9	14.8	13.3	Not Tested for VOCs	na
109	N KOOTENAI WATER #1 HAYDEN	1280095	nd	0.0174	48.2	nd	1.54	122	7.84	1.94	15.1	2.53	8.8	Bromdichloromethane	1.16
109	N KOOTENAI WATER #1 HAYDEN	1280095	nd	0.0174	48.2	nd	1.54	122	7.84	1.94	15.1	2.53	8.8	Dibromochloromethane	1.23
104	POST FALLS #3 IDAHO RD	1280147	0.00201	nd	102	1.03	3.79	253	7.08	8.97	21.7	11.6	14	Tested < MDL	0
103	POST FALLS #4 GREENSFERRY	1280147	0.00349	nd	96.4	0.962	3.19	453	6.57	9.59	22.1	9.98	9.2	Tested < MDL	0
105	POST FALLS #5 POLELINE	1280147	0.00332	0.0381	105	1.31	3.83	305	7.57	9.82	23.8	11.0	12.3	Tested < MDL	0
129	POST FALLS #6 - MULLAN	1280147	0.00365	nd	91.4	1.07	3.38	336	7.32	9.62	20.8	9.56	9.9	Tested < MDL	0
122	RATHDRUM - GRANGE	1280152	nd	0.221	102	1.43	7.54	247	7.85	4.84	27.3	8.20	8.6	Not Tested for VOCs	na
121	RATHDRUM - PINE STREET	1280152	0.00210	0.0423	115	1.36	4.15	272	7.76	6.01	27.8	11.0	8.1	Not Tested for VOCs	na
123	ROSS POINT - HWY 41	1280163	nd	nd	82.2	0.572	5.81	193.8	7.56	5.30	21.6	6.85	13.8	Tested < MDL	0
126	SILVER WATER ASSOCIATION	1280173	0.00378	0.0185	207	0.969	5.16	476	7.56	11.6	57.1	15.5	10.4	Not Tested for VOCs	na
131	SPIRIT LAKE #4	1280177	0.00196	nd	43.9	0.564	0.978	110	7.87	3.85	12.7	2.95	11.1	Not Tested for VOCs	na
117	USFS NURSERY	1280212	nd	nd	101	0.428	5.58	274	7.76	6.02	29.5	6.53	10.6	Tested < MDL	0